

CENTRIX MAGNET



PRODUCT DESCRIPTION

CENTRIX MAGNET CLAMP is used to secure the **HYDRO-PRUFE® PVC** membrane to the induction plate behind the membrane once the induction weld is complete. **CENTRIX MAGNET CLAMPS** comes in two versions. For vertical or overhead work magnet clamp XS6 may be used. For non overhead work version STD6 can be used.

PROPERTIES

<u>Description</u>		<u>Results</u>
Magnet Clamping force	60 mil	25lbs
Magnet Clamping force	80 mil	25lbs
Magnet Clamping force	100 mil	18lbs

PACKAGING

Sold in boxes of 25 minium.



INSTALLATION NOTES

- Ensure that magnet clamp is placed evenly over plate immediately after induction welding.
- Make sure surface of magnet clamp is clean and free of debris
- The magnet clamp must be left in place for a minium of 1 minute but it is recommended to increase this time.
- If the surface of the magnet clamp feels warm or hot let cool off and use alternating magnets

AVAILABILITY

CENTRIX MAGNET CLAMP is available from the manufacturer, vendors, or factory trained contractors.

The information, data and suggestions contained herein are believed to be reliable, based upon our knowledge and experience. For the most up to date information, please visit www.hydro-gard.com. HYDRO-GARD accepts no responsibility for the results obtained through application of this product. HYDRO-GARD reserves the right to update information without notice.

HYDRO-GARD LLC • 18340 Yorba Linda Blvd. Suite 107, Box 304, Yorba Linda, Ca 92886

Tel 562/ 944-7030 • Fax 562/ 944-6402 • www.hydro-gard.com