

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Hydro-Gard, LLC
18340 Yorba Linda Blvd.
Yorba Linda, CA 92886

Attn: Gregory S. Troyer
(562) 944-7030

RESEARCH REPORT: RR 26052
(CSI # 07 14 00)

BASED UPON ICC-ES EVALUATION
REPORT NO. ESR-3813

REEVALUATION DUE
DATE: July 01, 2021
Issued Date: June 01, 2019
Code: 2017 LABC

GENERAL APPROVAL – Reevaluation – Hydro-Tuff Hot Rubberized Asphalt Membrane for below grade waterproofing and dampproofing applied to foundation walls/ slab waterproofing.

DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, installation, conditions of use, and identification of Evaluation Report No. 3813; reissued June, 2018, report subject to renewal June 2019, of the ICC-ES Evaluation Services, LLC. The report, in its entirety, is attached and made part of this general approval.

The above system is approved for waterproofing when required by Section 1805.3 and damp proofing when required by Section 1805 of the 2017 City of Los Angeles Building Code.

The parts of Report No.ESR-3813 which are excluded on the attached copy have been removed by the Los Angeles City Building Department as not being included in this approval.

The approval is subject to the following conditions:

1. The products shall be delivered to the job site in sealed containers properly identified with the manufacturer's name and address; trade name of the product; Los Angeles research report number; and evaluation report number (ESR-3813)

RR 26052
Page 1 of 3

Hydro-Gard, LLC
RE: Hydro-Tuff

2. Except as specified herein, application of the system shall be in accordance with the manufacturer's instructions. A copy of the instructions shall be available at each job site.
3. Application of the product shall be accomplished by an applicator approved by the manufacturer and in writing by the manufacturer.
4. The membrane materials shall not be used with pneumatically applied concrete (gunite or shotcrete).
5. All surfaces to receive the product must be smooth, free of depressions, voids, protrusions, clean and free of unapproved curing compounds, form release agents and other surface contaminants.
6. Joints and penetrations to which the membrane is applied must be made watertight in accordance with the applicable code.
7. Hydro-Tuff membrane system must be applied at an overall nominal thickness of 215 mils and covered with a Hydro-Tuff PB-25 protection layer.
8. Hydro-Tuff is approved for use on the exterior horizontal and vertical surfaces of foundation walls of cast-in-place concrete, cement board or wood foundations. Other applications are outside the scope of this report.
9. The design and installation of the foundation drainage system is outside the scope of this report.
10. The maximum allowable hydrostatic pressure for the Hydro-Tuff system is 50 psi.

DISCUSSION

This report is in compliance with the 2017 City of Los Angeles Building Code.

The approval is based on tests and analyses in accordance with ICC-ES AC 29, dated June 2011 (editorially revised October 2014).

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

Hydro-Gard, LLC
RE: Hydro-Tuff

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

DAVID CHANG, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9814
Fax - 213-202-9943

BKR
RR26052
R05/21/2019
TLB1900113
1805.3

Attachments: ICC-ES Evaluation Report No. ESR-3813 (2 Pages).